

COLLIER COUNTY GOVERNMENT
GROWTH MANAGEMENT DIVISION / PLANNING AND REGULATION
2800 N. Horseshoe Drive, Naples FL 34104 * Phone (239) 252-2400

Outstanding Corrections

Date: January 21, 2015
Contact Name: CORRADI, MICHAEL & VALENTINA
Address: 1088 WISCONSIN DR
City, State Zip: NAPLES , FL 34103-
Fax: <NO FAX NUMBER>

PERMIT NO: PRBD2014072122801
APPLICATION NO: PRBD20140721228
JOB SITE ADDRESS: 1088 Wisconsin DR
Email:

Dear Applicant:

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below.

Submit 4 sets of revised sheets along with 4 letters of response addressing each item. All corrections must be clouded. **Corrections must be submitted in person, the GMD office receiving corrections is open until 4:00 pm. (NOTE: SIRE permit corrections must be resubmitted through SIRE)**

JOB DESCRIPTION: NEW OPEN CARPORT AND STORAGE
1088 WISCONSIN DR LOT 6

Rejected Review: Residential Review
Reviewed By: Michael Gibbons
Phone:239-252-2426 Email:michaelgibbons@colliergov.net

Correction Comment 1: Please provide the Florida State Product Approval with installation instructions or the Miami-Dade Notice of Acceptance with installation instructions for the following products:

1. NOA 11-1018.14 is missing pages 10 thru 23 of 23 for the Installation Instructions.
2. FPA #251 Cover Pages (2) is for 770 SGD BUT the Installation Instructions attached are for single door FPA # 7640.

Correction Comment 2: This review shall be considered incomplete pending receipt of the information requested. Subsequent reviews may reveal additional deficiencies.

Rejected Review: Health Review
Reviewed By: Duncan Freel
Phone:239-252-5526 Email:Duncan.Freel@flhealth.gov

Correction Comment 1: Health Department Review Corrections:

Septic system is near the proposed building. Provide a site plan with setbacks from septic system to the proposed carport and storage.

ATTENTION:

Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within **180 days** with corrected plans or an appeal to the Code Enforcement Board, the permit application will be canceled as per **Collier County Ordinance 2002-01, Section**,

104.5.1.1 to 104.5.1.4.

IMPORTANT:

The new Digital Flood Insurance Rate Map (DFIRM) will be effective on March 30, 2012. All development and building permit must be in compliance with the DFIRM flood zone and flood elevation requirements beginning on March 30, 2012. Please note that applications submitted prior to March 30, 2012, but issued after March 29, 2012, must be in compliance with the DFIRM requirements.