

COLLIER COUNTY GOVERNMENT
GROWTH MANAGEMENT DIVISION / PLANNING AND REGULATION
 2800 N. Horseshoe Drive, Naples FL 34104 * Phone (239) 252-2400

Outstanding Corrections

Date: April 12, 2012
Contact Name: B LAYTON LLC
Address: 5206 HAWKESBURY WAY
City, State Zip: NAPLES, FL 34119--
Fax: <NO FAX NUMBER>

PERMIT NO: PRBD2012030668801
APPLICATION NO: PRBD20120306688
JOB SITE ADDRESS: 8231 Bay Colony DR, Unit:BLDG
Email: blytonllc@comcast.net

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below.

Submit 5 sets of revised sheets along with 5 letters of response addressing each item. All corrections must be clouded. Submit all corrections in person.

PLEASE NOTE:

Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within six (6) months with corrected plans or an appeal to the Code Enforcement Board, the permit application will be canceled as per *Collier County Ordinance 2002-01, Section , 104.5.1.1 to 104.5.1.4.*

IMPORTANT:

The new Digital Flood Insurance Rate Map (DFIRM) will be effective on March 30, 2012. All development and building permit must be in compliance with the DFIRM flood zone and flood elevation requirements beginning on March 30, 2012. Please note that applications submitted prior to March 30, 2012, but issued after March 29, 2012, must be in compliance with the DFIRM requirements.

Date	Correction Code	Comments	Status	Reviewer	Contact Info
04/11/12	0	Clarify type of construction, plans indicate type IV, this is "heavy timber" per the present FBC, please update.	Outstanding	Tom Umscheid	(239) 252-2433 tomumscheid@colliergov.net
04/11/12	0	Clarify damage from hurricane "Wilma" this storm occurred in October of 2005! Please provide record of repair to structure, could not locate record of permit.	Outstanding	Tom Umscheid	(239) 252-2433 tomumscheid@colliergov.net
04/11/12	B082	Per Florida Building Code; Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed. Provide report from mold remediation agency, indicate all damage and extent of repairs required, plans simply state remove & replace drywall, cabinets etc.	Outstanding	Tom Umscheid	(239) 252-2433 tomumscheid@colliergov.net