

**COLLIER COUNTY GOVERNMENT**  
**GROWTH MANAGEMENT DIVISION / PLANNING AND REGULATION**  
**2800 N. Horseshoe Drive, Naples FL 34104 \* Phone (239) 252-2400**

**Outstanding Corrections**

**Date:** April 22, 2013  
**Contact Name:** CORRADI, MICHAEL & VALENTINA  
**Address:** 1088 WISCONSIN DR  
**City, State Zip:** NAPLES , FL 34103-  
**Fax:** <NO FAX NUMBER>

**PERMIT NO:** PRBD2012122603703  
**APPLICATION NO:** PRBD20121226037  
**JOB SITE ADDRESS:** 1088 Wisconsin DR  
  
**Email:** mkc@crnaples.com

Dear Applicant:

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below. All corrections must be clouded. **Corrections must be submitted in person, the office receiving corrections is open until 4:00 pm.**

JOB DESCRIPTION: REMODEL INTERIOR, ADD IMPACT WINDOWS IN EXISTING OPENINGS, REVISE ELECTRICAL ,REMODEL KITCHEN 1088 WISCONSIN DR LOT 6 2 BED 1 BATH RT

**Rejected Review: Residential Review**  
**Reviewed By: Michael Gibbons**  
**Phone:239-252-2426 Email:michaelgibbons@colliergov.net**

Correction Comment 1: Please provide the Florida State Product Approval with installation instructions or the Miami-Dade Notice of Acceptance with installation instructions for the following products:

1. Installation Instructions for the PGT 770 Door is missing pages 19 through 23.

Correction Comment 2: please clarify if the slab for new sunroom is existing and a new footing is going to be installed independent of slab or is the slab new and to be poured with new footings.

Correction Comment 3: Please clarify the complete roofing materials to be installed on existing roof.

Correction Comment 4: This review shall be considered incomplete pending receipt of the information requested. Subsequent reviews may reveal additional deficiencies

Submit 4 sets of revised sheets along with 4 letters of response addressing each item.

**PLEASE NOTE:**

Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within six **(6) months** with corrected plans or an appeal to the Code Enforcement Board, the permit application will be canceled as per **Collier County Ordinance 2002-01, Section, 104.5.1.1 to 104.5.1.4.**

**IMPORTANT:**

The new Digital Flood Insurance Rate Map (DFIRM) will be effective on March 30, 2012. All development and building permit must be in compliance with the DFIRM flood zone and flood elevation requirements beginning on March 30, 2012. Please note that applications submitted prior to March 30, 2012, but issued after March 29, 2012, must be in compliance with the DFIRM requirements.