



STATEMENT OF UTILITY PROVISIONS  
FOR PUD REZONE REQUEST

APPLICANT CONTACT INFORMATION

Name of Applicant(s): BCHD Partners III, LLC  
Address: 2600 Golden Gate Parkway city: Naples State: FL ZIP: 34105  
Telephone: 239-262-2600 Cell: \_\_\_\_\_ Fax: \_\_\_\_\_  
E-Mail Address: DGenson@barroncollier.com  
Address of Subject Property (If available): 3001 Santa Barbara Boulevard  
City: Naples State: FL ZIP: 34116

PROPERTY INFORMATION

Section/Township/Range: 29 / 49 / 26  
Lot: \_\_\_\_\_ Block: \_\_\_\_\_ Subdivision: \_\_\_\_\_  
Metes & Bounds Description: See Boundary Survey  
Plat Book: \_\_\_\_\_ Page #: \_\_\_\_\_ Property I.D. Number: 38170040001

TYPE OF SEWAGE DISPOSAL TO BE PROVIDED

Check applicable system:

- a. County Utility System
- b. City Utility System
- c. Franchised Utility System
- d. Package Treatment Plant
- e. Septic System

☒  
☐  
☐  
☐  
☐

Provide Name: \_\_\_\_\_  
(GPD Capacity): \_\_\_\_\_

TYPE OF WATER SERVICE TO BE PROVIDED

Check applicable system:

- a. County Utility System
- b. City Utility System
- c. Franchised Utility System
- d. Private System (Well)

☒  
☐  
☐  
☐

Provide Name: \_\_\_\_\_

Total Population to be Served: 21.5 ksf shopping center or 6 ksf gas station and 6.75 ksf fast food

Peak and Average Daily Demands:

A. Water-Peak: 17 gpm Average Daily: 18,270 GPD  
B. Sewer-Peak: 12 gpm Average Daily: 13,050 GPD

If proposing to be connected to Collier County Regional Water System, please provide the date service is expected to be required: 2020



COLLIER COUNTY GOVERNMENT  
GROWTH MANAGEMENT DEPARTMENT  
[www.colliergov.net](http://www.colliergov.net)

2800 NORTH HORSESHOE DRIVE  
NAPLES, FLORIDA 34104  
(239) 252-2400 FAX: (239) 252-6358

**Narrative statement:** Provide a brief and concise narrative statement and schematic drawing of sewage treatment process to be used as well as a specific statement regarding the method of affluent and sludge disposal. If percolation ponds are to be used, then percolation data and soil involved shall be provided from tests prepared and certified by a professional engineer.

---

Not applicable

---

**Collier County Utility Dedication Statement:** If the project is located within the service boundaries of Collier County's utility service system, a notarized statement shall be provided agreeing to dedicate the water distribution and sewage collection facilities within the project area to the Collier County Utilities. This shall occur upon completion of the construction of these facilities in accordance with all applicable County ordinances in effect at that time. This statement shall also include an agreement that the applicable system development charges and connection fees will be paid to the County Utilities Division prior to the issuance of building permits by the County. If applicable, the statement shall contain an agreement to dedicate the appropriate utility easements for serving the water and sewer systems.

---

See "Utility Dedication Statement" document included with Submittal 1.

---

**Statement of Availability Capacity from other Providers:** Unless waived or otherwise provided for at the pre-application meeting, if the project is to receive sewer or potable water services from any provider other than the County, a statement from that provider indicating adequate capacity to serve the project shall be provided.

	Potable Water		Sanitary Sewer	
	ADF (GPD)	Peak Day (gpm)	ADF* (GPD)	Peak Day (gpm)
<b>Scenario 1 - Retail and Office</b>	6,572	6.2	4,694	4.4
<b>Scenario 2 - Gas and Fast Food</b>	18,270	17.0	13,050	12.2

\* Sanitary sewer ADF calculated as Water ADF divided by 1.4

Scenario 1 - Retail and Office

21.5 ksf Retail

Retail / Office Flows

Calculate assumed retail floor area and number of restaurant seats:

Assume 15% of shopping center as restaurant use:

Total Commercial Floor Area = 21,500 sf

Assumed Restaurant Area = 15%

Assumed Restaurant Floor Area = 3,225 sf

Assume Restaurant Density = 45 sf / restaurant seat

Assumed Number of Restaurant Seats = 3,225 sf restaurant area

45 sf / restaurant seat

Assumed Number of Restaurant Seats = 72 restaurant seats

Calculate potable water demands from restaurant use:

Restaurant Average Daily Flow = 72 seats

40 GPD Wastewater  
seat

1.4 GPD Water  
GPD WW

Restaurant Average Daily Flow = 4,013 GPD

Restaurant Peak Day Demand = 4,013 Gal  
Day

1 Day  
1440 Minutes

1.35 Peak Day Factor

Restaurant Peak Day Demand = 3.8 gpm

Calculate potable water demands from retail use:

Retail Average Daily Flow = 18,275 sf

0.1 GPD Wastewater  
sf

1.4 GPD Water  
GPD WW

Retail Average Daily Flow = 2,559 GPD

Retail Peak Day Demand =  $\frac{2,559 \text{ Gal}}{\text{Day}} \times \frac{1 \text{ Day}}{1440 \text{ Minutes}} \times 1.35 \text{ Peak Day Factor}$

Retail Peak Day Demand = 2.4 gpm

Calculate average day potable water demands from shopping center use:

Restaurant Average Daily Flow = 4,013 GPD  
Retail Average Daily Flow = 2,559 GPD  

---

Shopping Center Average Daily Flow = 6,572 GPD

Calculate peak day potable water demands from shopping center use:

Restaurant Peak Day Demand = 3.8 gpm  
Retail Peak Day Demand = 2.4 gpm  

---

Shopping Center Average Daily Flow = 6.2 gpm

Summary

Proposed Land Use	Potable Water		Sanitary Sewer	
	ADF (GPD)	Peak Day (gpm)	ADF* (GPD)	Peak Day (gpm)
Shopping Center	6,572	6.2	4,694	4.4

\* Sanitary sewer ADF calculated as Water ADF divided by 1.4

Scenario 2 - Gas and Fast Food

6 ksf gas station convenience store  
6.75 ksf fast food restaurant

Gas Station Flows

Water closet demand for service station open greater than 16 hours per day

Gas Station WC Average Daily Flow =

3 water closets	325 GPD	1.4 GPD Water
	Water Closet	GPD WW

Gas Station WC Average Daily Flow =

1,365 GPD

Gas Station WC Peak Day Demand =

1,365 Gal	1 Day	1.35 Peak Day Factor
Day	1440 Minutes	

Gas Station WC Peak Day Demand =

1.3 GPD

For carry out food service operations within gas station

Gas Station Store Average Daily Flow =

6,000 sf building area	50 GPD	1.4 GPD Water
	100 sf	GPD WW

Gas Station Store Average Daily Flow =

4,200 GPD

Gas Station Store Peak Day Demand =

4,200 Gal	1 Day	1.35 Peak Day Factor
Day	1440 Minutes	

Gas Station Store Peak Day Demand =

3.9 GPD

Per food service employee within gas station

Per employee Average Daily Flow =

5 employees	15 GPD	1.4 GPD Water
	employee	GPD WW

Per Employee Average Daily Flow =

105 GPD



Restaurant Peak Day Demand =

12,600 Gal

Day

1 Day

1440 Minutes

1.35 Peak Day Factor

Restaurant Peak Day Demand = 11.8 gpm

Summary

Proposed Land Use	Potable Water		Sanitary Sewer	
	ADF (GPD)	Peak Day (gpm)	ADF* (GPD)	Peak Day (gpm)
Gas Station w/ Convenience Store	5,670	5.2	4,050	3.8
Fast Food Restaurant	12,600	11.8	9,000	8.4
Total for Scenario	18,270	17.0	13,050	12.2

\* Sanitary sewer ADF calculated as Water ADF divided by 1.4