

Sharon Umpenhour

From: Dan Waters <DWaters@barroncollier.com>
Sent: Thursday, March 07, 2019 9:31 AM
To: Sharon Umpenhour
Subject: FW: [External] RE: Pelican Nursery PUD

Fyi – pls upload this when we resubmit. This is the confirmation from Craig Pajer that the county system has capacity.

Dan

From: PajerCraig <Craig.Pajer@colliercountyfl.gov>
Sent: Thursday, March 7, 2019 9:28 AM
To: Dan Waters <DWaters@barroncollier.com>
Subject: [External] RE: Pelican Nursery PUD

Mr. Waters,

Please be advised that our wastewater transmission system can handle the design peak hour flow of 452 gpm proposed for this new development.

Craig J. Pajer, P.E.
EPMD Principal Project Manager

Under Florida Law, e-mail addresses are public records. If you do not want your e-mail address released in response to a public records request, do not send electronic mail to this entity. Instead, contact this office by telephone or in writing.