

COLLIER COUNTY GOVERNMENT
GROWTH MANAGEMENT DIVISION / PLANNING AND REGULATION
2800 N. Horseshoe Drive, Naples FL 34104 * Phone (239) 252-2400

Outstanding Corrections

Date: December 17, 2013
Contact Name: WATHCO INC
Address: 5470 TECHNOLOGY PKWY
City, State Zip: BRASELTON, GA 30517--
Fax: (770) 967-6740

PERMIT NO: PRBD2013102714202
APPLICATION NO: PRBD20131027142
JOB SITE ADDRESS: 2380 Vanderbilt Beach RD

Email:john ritter@hotmail.com

Dear Applicant:

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below. All corrections must be clouded. **Corrections must be submitted in person, the office receiving corrections is open until 4:00 pm.**

JOB DESCRIPTION: REMOVE SCROOL WORK ADD EIFS PANELS TO EXISTING PARAPET WALLS. REPAINT. INCREASE FRONT ENTRY FASCIA HEIGHT 18"2380 VANDERBILT

Rejected Review: Structural Review
Reviewed By: Jonathan Walsh
Phone:239-252-2962 Email:jonathanwalsh@colliergov.net

Correction Comment 1: It was noted that the previously approved wall detail complied with section 2303.2 as required in section 602.3 for Fire-retardant treated wood. However this revision undoes that approval. As discussed the contractor/ design professional shall submit for review an equal alternative per section 104.11 of the FBC, to date a complete and approved document has not been submitted supporting this revised changed. Please clarify.

Rejected Review: Fire Review
Reviewed By: Jackie de la Osa
Phone:239-687-5650 Email:jdelaosa@ccfco.org

Correction Comment 1: Plan states the fire retardant information has been provided, but it is not attached to the plans. Please provide.

Correction Comment 2: Additonal requirements may become evident when the above is provided for review.

Submit 5 sets of revised sheets along with 5 letters of response addressing each item.

PLEASE NOTE:

Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within **180 days** with corrected plans or an appeal to the Code Enforcement Board, the permit application will be canceled as per **Collier County Ordinance 2002-01, Section, 104.5.1.1 to 104.5.1.4.**

IMPORTANT:

The new Digital Flood Insurance Rate Map (DFIRM) will be effective on March 30, 2012. All development and building permit must be in compliance with the DFIRM flood zone and flood elevation requirements beginning on March 30, 2012. Please note that applications submitted prior to March 30, 2012, but issued after March 29, 2012, must be in compliance with the DFIRM requirements.