

COLLIER COUNTY GOVERNMENT
GROWTH MANAGEMENT DIVISION / PLANNING AND REGULATION
2800 N. Horseshoe Drive, Naples FL 34104 * Phone (239) 252-2400

Outstanding Corrections

Date: June 04, 2015
Contact Name: Firepower Fireworks Inc
Address: 5753 Elizabeth Ann Way
City, State Zip: Fort Myers , FL 33912
Fax: <NO FAX NUMBER>

PERMIT NO: PRFR2015051657901
APPLICATION NO: PRFR20150516579
JOB SITE ADDRESS: 3356 Tamiami TRL E, Unit:
Email: almueller@fpfireworks.com

Dear Applicant:

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below.

Submit 3 sets of revised sheets along with 3 letters of response addressing each item. All corrections must be clouded. **Corrections must be submitted in person, the GMD office receiving corrections is open until 4:00 pm. (NOTE: SIRE permit corrections must be resubmitted through SIRE)**

JOB DESCRIPTION: TENT FIREWORK SALES 1.4 G UN0336 TUP PL20150001210,
3356 TAMIAMI TRL E

Rejected Review: Fire Review
Reviewed By: Ame Davis
Phone:239-252-7517 Email:AmeDavis@colliergov.net

Correction Comment 1: FI Status Chapter 791.1 Seasonal retailer, selling of sparklers June 20th though July 5th and December 10th thru January 2nd only.

Correction Comment 2: Provide Flame certificate for tent-2011 NFPA 102: 8.3.

Correction Comment 3: Site Plan 5th ed FFPC NFPA 1124: 7.4.2
Provide details on plans for vehicle access and parking areas.
Provide location of the mobile storage unit that will be used as fireworks storage facility. Shall not be less than 10 ft from the sales tent

Correction Comment 4: Fireworks discharge. FFPC 5th ed NFPA 1: 65.10.3.8
Acknowledge on plans that signage will be provided that states "NO FIREWORKS DISCHARGED WITHIN 300 FEET"

Correction Comment 5: Portable Fire Extinguishers
Provide on plans an extra high extinguisher, pressurized water type fire extinguisher and multipurpose extinguishers
The maximum travel distance to reach and extinguisher shall not exceed 35ft. 5th ed FFPC NFPA 1:65.10.4.5.2

Correction Comment 6: No Smoking signs- "FIREWORKS-NO SMOKING" FFPC 5TH ED NFPA 1:65.10.3.11
Identify on plans

Correction Comment 7: Means of Egress Requirements 5th ed FFPC NFPA1:65.10.3.14
Revise plans to show adequate exits.
Show travel distance, aisle width and aisle arrangements- Means of egress, including but not limited to aisles, doors, and exit

discharge, shall be clear at all times
Provide exit signs and emergency lighting

Correction Comment 8: Retail Sales Displays 5th ed FFPC NFPA 1:65.10.3.15.2

Provide the dimensions of tent to scale and the layout of floor plan. Include shelving and height of displays complying with the requirements of this section.

Correction Comment 9: Provide source of power to this facility.

Provide location of generator and fuel source in compliance with NFPA1124.7.4.92

Correction Comment 10: Provide information of tent securing for non business hours and during rain storms. (tent sides, fencing, etc)

Correction Comment 11: Quantity Limitation 5th ed FFPC NFPA 1:65.10.4.10

Shall not exceed 40 percent of the available floor area within the retail sales area

Correction Comment 12: Records 5th ed FFPC NFPA 1:65.10.3.24

Provide inventory of fireworks and sparklers for this location.

Correction Comment 13: Acknowledge on plans a 704 markings placard for explosive firework storage will be posted

ATTENTION:

Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within **180 days** with corrected plans or an appeal to the Code Enforcement Board, the permit application will be canceled as per **Collier County Ordinance 2002-01, Section, 104.5.1.1 to 104.5.1.4.**

IMPORTANT:

The new Digital Flood Insurance Rate Map (DFIRM) will be effective on March 30, 2012. All development and building permit must be in compliance with the DFIRM flood zone and flood elevation requirements beginning on March 30, 2012. Please note that applications submitted prior to March 30, 2012, but issued after March 29, 2012, must be in compliance with the DFIRM requirements.