

COLLIER COUNTY GOVERNMENT
GROWTH MANAGEMENT DIVISION / PLANNING AND REGULATION
2800 N. Horseshoe Drive, Naples FL 34104 * Phone (239) 252-2400

Outstanding Corrections

Date: December 23, 2015
Contact Name: NOWA CONSTRUCTION, CORP.
Address: 4535 10TH ST NE
City, State Zip: NAPLES, FL 34120
Fax: <NO FAX NUMBER>

PERMIT NO: PRBD2015123845501
APPLICATION NO: PRBD20151238455
JOB SITE ADDRESS: 4570 10th ST NE
Email: Nunesfs@icloud.com

Dear Applicant:

Plans submitted with the referenced permit have been reviewed. We are unable to approve your permit application for the reason(s) indicated below.

Submit 4 sets of revised sheets along with 4 letters of response addressing each item. All corrections must be clouded. **Corrections must be submitted in person, the GMD office receiving corrections is open until 4:00 pm. (NOTE: SIRE permit corrections must be resubmitted through SIRE)**

JOB DESCRIPTION: CONSTRUCTION OF SFR
4570 10TH ST NE

3 bed / 3 w.c. rm

Rejected Review: Residential Review
Reviewed By: Robert Moore
Phone: 239-252-5705 Email: RobertMoore@colliergov.net

Correction Comment 1: 1. Drawings must have design professionals original signature with raised or wet seal.

Correction Comment 2: This review shall be considered incomplete pending receipt of the information requested. Subsequent reviews may reveal additional deficiencies

Rejected Review: FEMA Review
Reviewed By: Robert Moore
Phone: 239-252-5705 Email: RobertMoore@colliergov.net

Correction Comment 1: 1. Garage finish floor elevation is below base flood elevation. Please provide flood relief vents and flood resistant material for the garage area.

Rejected Review: Health Review
Reviewed By: Rachel VanBlaricom
Phone: 239-252-5524 Email: Rachel.VanBlaricom@flhealth.gov

Correction Comment 1: Health Department Review Corrections: Need verification of soils licensed evaluator.

ATTENTION:
Collier County Plan Review and Inspections routinely reviews all outstanding permit applications in order to determine their

status. The review process includes appropriate responses from the permit applicant when the permit cannot be approved. When the applicant is advised of deficiencies and does not respond within **180 days** with corrected plans or an appeal to the Code Enforcement Board, the permit application will be canceled as per ***Collier County Ordinance 2002-01, Section, 104.5.1.1 to 104.5.1.4.***

IMPORTANT:

The new Digital Flood Insurance Rate Map (DFIRM) will be effective on March 30, 2012. All development and building permit must be in compliance with the DFIRM flood zone and flood elevation requirements beginning on March 30, 2012. Please note that applications submitted prior to March 30, 2012, but issued after March 29, 2012, must be in compliance with the DFIRM requirements.