

Zepp, Nico

From: Dan Wadsworth <Dan@wadsworthoneal.com>
Sent: Wednesday, January 24, 2018 2:12 PM
To: Daniel Summers
Cc: Nobrega, Rod; Wiley Parker; Sandy Koehler; Zepp, Nico
Subject: [External] RE: MPGL - Permitting requirements

Generator buildings are not air conditioned and do not require energy calculations.

Dan Wadsworth PE

dan@wadsworthoneal.com

Wadsworth O'Neal Associates, Inc.
Mechanical / Electrical Consulting Engineers
phone (239) 245-8728
cell (239) 671-4272

From: Daniel Summers [mailto:daniels@bsswarchitects.com]
Sent: Wednesday, January 24, 2018 2:10 PM
To: Dan Wadsworth <Dan@wadsworthoneal.com>
Cc: Nobrega, Rod <RNobrega@suffolk.com>; Wiley Parker <wileyparker@londonbay.com>; Sandy Koehler <sandyk@bsswarchitects.com>; Zepp, Nico <NZepp@suffolk.com>
Subject: RE: MPGL - Permitting requirements

Dan:

Please see note below regarding generator buildings?

Thanks,

Dan

Daniel A. Summers, AIA



BSSW Architects, Inc.

949 Central Avenue
Naples, Florida 34102

Voice: 239.643.3103 Fax: 239.643.7435

E-Mail: DanS@BSSWarchitects.com

This e-mail and any files transmitted with it are confidential and are intended solely for the use of the individual or entity

they are addressed. If you are NOT the intended recipient or the person responsible for delivering the e-mail to the intended recipient, be advised that you have received this e-mail in error and that any use, dissemination, forwarding, printing, or copy of this e-mail is strictly prohibited. If you have received this communication in error, kindly notify us immediately by e-mail reply to the originating address.

From: Zepp, Nico [<mailto:NZepp@suffolk.com>]
Sent: Wednesday, January 24, 2018 1:49 PM
To: Daniel Summers <daniels@bsswarchitects.com>; Sandy Koehler <sandyk@bsswarchitects.com>; Wiley Parker <wileyparker@londonbay.com>
Cc: Nobrega, Rod <RNobrega@suffolk.com>
Subject: MPGL - Permitting requirements

Dan / Sandy,

Good afternoon. I just received a notice from Collier County requiring a few additional permitting documents. Can you please provide the following:

- Digitally signed and sealed site survey for each building type including generator and generator / fire pump buildings.
- Energy calcs for generator and generator / fire pump buildings.

Thanks for your help.

Wylie,

I also need signatures on from your office on the permit apps. Originally this did not appear as a requirement to me, but they are. I'll send the pages for signatures and notary under a separate email.

There are a few other requirements I am working on as well.

Thanks,



Nico Zepp
Project Manager

D | +15612823021
C | +18503903696
F | 239-405-8123

We are transforming an industry. [Join us.](#)

www.suffolk.com



Please consider the environment before printing this email