



NORTH COLLIER FIRE CONTROL AND RESCUE DISTRICT

Prevention Bureau

BOARD OF FIRE COMMISSION

J. Christopher Lombardo, Chairman ■ Norman E. Feder, Vice Chairman ■ Richard Hoffman, Secretary-Treasurer
James Burke, Commissioner ■ Ramon E. Chao, Commissioner ■ Christopher L. Crossan, Commissioner
Margaret Hanson, Commissioner ■ John O. McGowan, Commissioner

August 4, 2015

Ms. Krystle Weems
Davidson Engineering, Inc.
4365 Radio Road, Suite 201
Naples, FL 34104

Re: Apparatus Access

Ref: Cameron Commons Tract 5 (PL20140002531)

Ms. Weems,

I have received your request for a waiver of the turning radius requirements of Collier County Fire Prevention and Protection Code Policy and Procedure Manual Article Number ACC 09-4. The turn in question is located at the Northwest corner of the above referenced project.

The Auto-Turn simulation provided shows entrance from the Northeast from Goodland Bay Dr and continuing down the rear length of the building as being sufficient and consistent with tactics we employ for non-building related fire incidents. The addition of a Designated Fire Lane with proper signage on the existing parking access road as shown on sheet 8 of 11 dated 7/30/2015 is satisfactory to approve the request.

Dale E. Fey, Jr.
Fire Marshal
North Collier Fire Control/Rescue District
6495 Taylor Rd.
Naples, Fl. 34109
dfey@northcollierfire.com
239-597-9227 - Office
239-552-1365 – Direct